

Table of Contents

Table of Contents	1
NPDES Sanitary Sewer Overflow (SSO) Event Reporting Form	2
(Submission #: HQP-N80G-MTAFC, version 1)	2
Details	2
Form Input	2
General Instructions	2
Processing	2
Permittee Information	2
Facility/Site Information	2
Assigned SSO ID	3
SSO Event - Information	3
SSO Event - Corrective Action	4
Additional Attachments	4
General Comments	5
Attachments	5
Status History	5
Agreements and Signature(s)	6

NPDES Sanitary Sewer Overflow (SSO) Event Reporting Form

version 1.5

(Submission #: HQP-N80G-MT AFC, version 1)

Details

Submission Alias NPDES Sanitary Sewer Overflow (SSO) Event Report

SSO ID SSO-00214453

Submission ID HQP-N80G-MT AFC

Status Submitting

Form Input

General Instructions

Processing

NOTE: You should choose the correct status for this SSO notification/report EACH time you submit a notification/report.

If you are able to complete all of the information in the first submittal, please indicate the status of "Submit both the Initial 24-hour notification and 5-day report concurrently."

Indicate which of the following describes the status of this SSO notification/report:

Submit both the Initial 24-hour notification and 5-day report concurrently

Prior to submitting this notification/report through AEPACS, did you make the first notification of this SSO to the Department by a method other than AEPACS (e.g. SSO Hotline, Fax, Email)?

No

Regardless of the notification method used to first notify the Department of this SSO event (i.e. AEPACS, SSO hotline, fax, etc), was the initial notification made to the Department within 24 hours of becoming aware of the event?

Yes

Permittee Information

Permit Number

AL0049042

Permittee

The Utilities Board of the City of Foley

Facility/Site Information

Facility Name

Foley WWTP

Facility County

Baldwin

Assigned SSO ID

Assigned SSO ID

SSO-00214453

SSO Event - Information

Date/Time SSO Event Started:

Date	Time
06/27/2026	06:00 pm

Is the SSO on-going?

No

Date/Time SSO Event Stopped:

Date	Time
06/28/2026	04:00 am

Did the SSO occur during wet weather?

No

Was the SSO caused by an extreme weather event (e.g. hurricane) that flooded the ENTIRE sewer system?

No

Report Estimated Volume Discharged as

Value

Estimated Volume Discharged (in gallons)

29620

Indicate source of discharge event

Broken Line

County in which SSO occurred (check all that apply)

Baldwin

Note

For detailed information on how to place a point on the map, please click the Map Help link below. Also, when reporting for an SSO(s) caused by an extreme weather event, please specify a general location for the SSO(s):

[Map Help link](#)

Latitude/Longitude of discharge

30.391872,-87.6796368

Note

Please specify either the street address or location description for the discharge

Street Address

220 East Michigan Avenue

City

Foley

State

AL

ZIP Code

36535

Location Description

NONE PROVIDED

Known or suspected cause of the discharge

An underground utility contractor bored into the sanitary sewer forcemain. The contractor removed their equipment from the site and did not report damage to the infrastructure.

Destination of discharge

Ground Absorbed
Other (Please Describe)

Please describe the Other destination(s) of the discharge:

The SSO was contained in the drainage ditch associated with the sanitary sewer force main. The lower end was dammed up to contain the release. The overflow was hauled away by vac truck.

Did the discharge reach a designated swimming water?

No

Monitoring of the receiving water (i.e. visual survey or water quality sampling) is:

Not Performed

Was the affected area cleaned?

Yes

Was the affected area disinfected?

Yes

Are you aware of any other potential health or environmental impacts?

No

SSO Event - Corrective Action

Describe corrective actions taken, plans to eliminate future discharges, and actions or plans to mitigate impacts to the environment and/or public health.

Crews responded to the SSO site and began containing the release. Once the 811 emergency line locates were clear to begin excavation, the crew discovered that the sanitary sewer force main had been struck by a boring machine used by an underground utility contractor. The 811 ticket for the contractor working at this address has been found, and we will be in touch with them.

Please attach supporting information, if applicable:

06-27-2026 - 220 E Michigan SSFM Strike.jpg - 06/28/2026 01:20 PM
Comment
NONE PROVIDED

Indicate efforts to notify public (check all that apply):

Press Release

Press release date:

06/28/2026

Indicate Other Officials Notified (check all that apply):

County Health Department

County Health Department notification date:

06/28/2026

Other States notified:

NONE PROVIDED

Were any public water supply intake locations affected?

No

Additional Attachments

Additional Attachments

NONE PROVIDED

Comment

NONE PROVIDED

General Comments

General Comments (Optional)

NONE PROVIDED

Attachments

Date	Attachment Name	Context	Confidential?	User
6/28/2026 1:20 PM	06-27-2026 - 220 E Michigan SSFM Strike.jpg	Attachment	No	Jason Skelton

Status History

	User	Processing Status
6/28/2026 1:07:36 PM	Jason Skelton	Draft
6/28/2026 1:48:24 PM	Jason Skelton	Signing
6/28/2026 1:48:25 PM	Jason Skelton	Submitting

Agreements and Signature(s)

SUBMISSION AGREEMENTS

- I am the owner of the account used to perform the electronic submission and signature.
- I have the authority to submit the data on behalf of the facility I am representing.
- I agree that providing the account credentials to sign the submission document constitutes an electronic signature equivalent to my written signature.
- I have reviewed the electronic form being submitted in its entirety, and agree to the validity and accuracy of the information contained within it to the best of my knowledge.

I certify that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information to be true, accurate, and complete. I am aware that there are significant penalties for knowingly submitting false information, including the possibility of fine and imprisonment.

Signed Jason Skelton on 06/28/2026 at 1:48 PM
By