



WATER METER MATERIAL SCHEDULE

1. METER YOKE
  - A. FOR  $\frac{3}{4}$ " SERVICE SHALL BE FORD LINE SETTER LF-LSVBH41-233W-Q-NL, MUELLER  $\frac{3}{8}$ " X  $\frac{3}{4}$ " B2418R-2, OR APPROVED EQUAL.
  - B. FOR 1" SERVICE SHALL BE FORD LINE SETTER LS-VBH41-444W-Q-NL, MUELLER B2418R-2, OR APPROVED EQUAL.
  - C. FOR 1.5" SERVICE SHALL BE FORD LINE SETTER LF-VBHH76-12HB-11-66 CSTR, MUELLER B2423-2-99000 OR APPROVED EQUAL.
  - D. FOR 2.0" SERVICE SHALL BE FORD LINE SETTER LF-VBHH77-12HB-11-77 CSTR, MUELLER B2423-2-99000 WITH 2" SPACER, OR APPROVED EQUAL.
2. WATER METER PROVIDED AND INSTALLED BY RIVIERA UTILITIES
3. METER BOX AND COVER
  - A. FOR  $\frac{3}{4}$ " SERVICE SHALL BE STANDARD SIZE DEXOL 1419-12 CIR, CARSON DDX1419-12-CIR, OR APPROVED EQUAL.
  - B. FOR 1" SERVICE SHALL BE LARGE SIZE DEXOL 1419-12 CIR, CARSON DDX1419-12-CIR, OR APPROVED EQUAL.
  - C. FOR 1.5" AND 2" SERVICES SHALL BE JUMBO SIZE DEXOL 1419-12 CIR, CARSON DDX1419-12-CIR, OR APPROVED EQUAL.
4. CUSTOMER-SIDE SHUT-OFF VALVE, VALVE BOX AND SERVICE PIPING (BY OTHERS) INSTALLED BETWEEN ONE TO TWO FEET FROM THE METER BOX.

DETAIL NOTES:

1. CORPORATION STOPS WHERE REQUIRED OR DIRECTED SHALL HAVE STANDARD CC CORPORATION STOP THREAD ON INLET AS SPECIFIED BY AWWA C800 AND COPPER SIZE O.D. OUTLET SUITABLE FOR SPECIFIED SERVICE PIPING. CORPORATION STOPS MAY BE TAPPED DIRECTLY INTO DUCTILE IRON AND C900 PVC WATER MAINS ONLY. CORPORATION STOPS SHALL BE TAPPED INTO OTHER EXISTING WATER MAINS ONLY BY MEANS OF A BRONZE SERVICE CLAMP (MUELLER H1300 SERIEIS, FORD S70 SERIES, OR EQUAL)
2. REFER TO RIVIERA UTILITIES' STANDARD SPECIFICATIONS FOR WATER MAINS, MOST RECENT VERSION, TO CONFIRM CURRENT SPECIFICATIONS AND MODEL NUMBERS FOR MATERIALS INDICATED ON THIS DETAIL. WHEN IN CONFLICT, THE STANDARD SPECIFICATIONS SHALL CONTROL.

ELEVATION VIEW

N.T.S.

**RIVIERA  
UTILITIES**



EASTERN DIVISION  
GAS, WATER, & WASTEWATER DEPARTMENT  
413 EAST LAUREL AVENUE  
FOLEY, ALABAMA 36535  
251.943.5001

**WATER DETAILS**

TYPICAL WATER SERVICE METER DETAIL (UP TO 2-INCH)

DATE ISSUED  
09-01-17

SHEET NO.  
W-1