


CUSTOMER IS RESPONSIBLE FROM METER YOKE TO BUILDING

BUILDING



WATER MAIN

\_\_\_\_\_  
 APPLICANT'S PRINTED NAME

\_\_\_\_\_  
 APPLICANT'S SIGNATURE

\_\_\_\_\_  
 DATE

**NOTES:**

1. THE CONTRACTOR SHALL MAKE THE CONNECTION TO THE METER YOKE.
2. AFTER THE CONNECTION IS MADE TO THE METER YOKE BY THE CONTRACTOR, INCLUDING ALL ITEMS SHOWN ON THE DIAGRAM TO THE LEFT, THE APPLICANT OR CONTRACTOR SHALL CALL RIVIERA TO SCHEDULE THE METER TO BE SET. METER SETS CAN BE SCHEDULED MONDAY THROUGH FRIDAY (EXCLUDING HOLIDAYS) BETWEEN 8AM AND 3PM.
3. FOR TEMPORARY SERVICE, PLACE A SHUT OFF VALVE APPROXIMATELY ONE (1) FOOT FROM THE METER BOX WITH A MINIMUM OF 10 FEET OF PIPE AND A HOSE BIB IN ACCORDANCE WITH THE DIAGRAM TO THE LEFT. A 3/4 INCH FEMALE FITTING IS REQUIRED TO CONNECT TO METER YOKE.
4. IF YOU HAVE AN EXISTING WELL, THE WELL PIPING MUST BE PHYSICALLY DISCONNECTED FROM THE BUILDING AND SERVICE PIPING.
5. IF THE CONTRACTOR CHANGES THE FINISHED GRADE IN THE AREA SURROUNDING THE EXISTING METER BOX, THE CONTRACTOR SHALL BE RESPONSIBLE FOR ADJUSTING THE METER BOX TO THE NEW FINISHED GRADE ELEVATION AT NO ADDITIONAL COST TO RIVIERA UTILITIES.
6. ANY DAMAGE CAUSED BY THE APPLICANT, CONTRACTOR, OR THEIR ASSIGNS TO THE METER BOX, METER YOKE, METER, VALVES OR PIPING SHALL BE REPAIRED OR REPLACED AT NO ADDITIONAL COST TO RIVIERA UTILITIES.
7. IF THE WATER SERVICE IS IN CONFLICT WITH A DRIVEWAY, CULVERT, OR OTHER INFRASTRUCTURE, THE APPLICANT SHALL BE RESPONSIBLE FOR PAYING RIVIERA UTILITIES' TO EITHER RELOCATE THE SERVICE OR HAVE A NEW SERVICE SET AND THE OLD SERVICE RETIRED.

**RIVIERA UTILITIES**

413 East Laurel Ave.  
 Foley, Alabama 36535

DESIGN	GARY RICHMOND	APPROVED	TONY SCHACHLE
DRAWN	COREY MCCLELLAN	APPROVED	TONY SCHACHLE
ENG	JASON SKELTON	APPROVED	TONY SCHACHLE
PRJ MGR	TONY SCHACHLE	DATE	12/19/2018
CHECK	KEVEN WILLIAMS		



RIVIERA UTILITIES  
 WATER SERVICE CONNECTION

SCALE	N.T.S.
DWG NO.	20181219WSD
SHEET	1 of 1